## CHECKLIST (to be completed by site manager/supervisor)

Company:				
Site:				
Plot:		Site manager/supervisor:		
Ref.	Item		Yes No	Inspected (initials & date)
1.	Has training been received from CMS Danskin			(Illitials & date)
2.	Are precast concrete planks 150mm (min) thick and of mass per unit area 300 kg/m² (min)?			
3.	Are inner leaves to external (flanking) walls of the correct block density?			
4.	Are joints between precast concrete planks grouted and sealed?			
5.	Are precast concrete planks built into the masonry walls?			
6.	Is the Regupol Quietlay covering the whole floor slab?			
7.	Is the Regupol Quie	tlay taken min 100mm up the wall?		
8.	Are all joints taped	with Regupol Tape?		
9.	Are the skirting boar screed by the Regu	rds and wall linings isolated from the pol Quietlay?		
10.	Are all ceiling board joints sealed with tape or caulked with sealant?			
11.	Are service pipes wrapped in quilt and boxed in with two layers of nominal 8 kg/m² gypsum-based board?			
12.	Is separating floor s	atisfactorily complete?		
Contact details for technical assistance from CMS Danskin, supplier of Regupol Quietlay resilient layer system:  Telephone: 01925 577711 Fax: 01925 577733 E-mail: info@cmsdanskin.co.uk				
		any corrective action)		
Site manager/supervisor signature				

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.

<sup>®:</sup> UK registered trade mark no. 2291665

тм: trade mark

<sup>©</sup> Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.