

CHECKLIST (to be completed by site manager/supervisor)

Company: _____

Site: _____

Plot: _____ Site manager/supervisor: _____

Ref.	Item	Yes (✓)	No (✓)	Inspected (initials & date)
1.	Are solid timber joists at least 220mm deep, or at least 240mm deep if joists installed at greater than 400mm centres?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
2.	Has quilt (min 100mm thick) been fitted between the joists?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
3.	Are resilient ceiling bars fitted at right angles to the joists?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
4.	Has ceiling system been fitted in accordance with the manufacturer's instructions?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
5.	Is floor decking 11mm thick (min); or 15mm thick (min) if joists at greater than 400mm centres?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
6.	Has floating floor treatment been fitted in accordance with the manufacturer's instructions?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
7.	Has 60mm quilt been fitted between the floor battens?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
8.	Is ceiling treatment CT1™, CT2™ or CT3™ fixed to the resilient bars with correct screws such that the screws do not touch or penetrate the joists?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
9.	Are all joints sealed with tape or caulked with sealant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
10.	Are vertical service pipes wrapped in quilt and boxed in with two layers of gypsum-based board combined nominal mass per unit area of 16 kg/m²?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
11.	Have all resilient flanking strips been fitted?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
12.	Is separating floor satisfactorily complete?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>

Notes (include details of any corrective action)

Site manager/supervisor signature

©: UK registered trade mark no. 2291665

™: trade mark

© Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.