CHECKLIST (to be completed by site manager/supervisor)

Com	ipany:			
Site:				
Plot:		Site manager/supervisor:		
Ref.	Item		Yes No	
Ι.		blocks dense aggregate 3) as featured on the list of acceptable details.com)?		(initials & date)
2.	Are blocks laid for the full 215mm width of the wall (i.e. 215mm blocks laid on side)?			
.	Is blockwork laid single course stretcher bond?			
I .	Is separating wall breaking the continuity of the inner leaf? (i.e. is the face of the separating wall abutted and tied or bonded into the inner leaf)			
5.	Are cavity stops ins	talled?		
	Are all joints fully fill	ed?		
-		oat applied to the whole wall face? y be omitted between floor joists/beams)		
3.	Is render or parge c finished?	oat at least 13mm thick and scratch		
)_	ls mass per unit are 12.5 kg/m²?	a of the gypsum based board at least		
0.	Are all junctions of voor caulked with sea	vall and ceiling boards sealed with tape ant?		
1.	Is separating wall sa	atisfactorily complete?		
Not	t es (include details o	any corrective action)		
Site	manager/supervisor	signature		

Copyright in the contents of this handbook is owned by Robust Details Limited. No copying or reproduction of the contents is permitted without the consent of Robust Details Limited with the exception of the checklists. The checklists may be copied and used freely.