

CHECKLIST (to be completed by site manager/supervisor)

Company: _____

Site: _____

Plot: _____ Site manager/supervisor: _____

| Ref. | Item | Yes (✓) | No (✓) | Inspected (initials & date) |
|------|--|--------------------------|--------------------------|--------------------------------|
| 1. | Is separating wall cavity at least 75mm? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 2. | Is external (flanking) wall cavity at least 50mm? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 3. | Are separating wall blocks Plasmor "Aglite Ultima" blocks? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 4. | Are external (flanking) wall blocks Plasmor "Aglite Ultima" blocks? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 5. | Is cavity free from droppings and debris? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 6. | Are separating wall ties Approved Document E "Tie type A" (see appendix A)? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 7. | Are cavity stops installed? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 8. | Are joints fully filled? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 9. | Are voids around floor joists, chases, etc. fully filled/sealed? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 10. | Is render coat applied to the whole wall face (except where it may be omitted between floor joists/beams)? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 11. | Where there is a separating floor (e.g. flats/apartments), has the correct flanking/isolation been provided to the perimeter of the floating floor/screed? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 12. | Are all junctions of wall and ceiling boards sealed with tape or caulked with sealant? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |
| 13. | Is separating wall satisfactorily complete? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="text"/> |

Contact details for technical assistance from Plasmor, manufacturer of "Aglite Ultima" lightweight aggregate blocks:
Telephone: 01977 673221 Fax: 01977 607071 E-mail: knott@plasmor.co.uk

Notes (include details of any corrective action)

Site manager/supervisor signature

©: UK registered trade mark no. 2291665

™: trade mark

© Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.