

CHECKLIST (to be completed by site manager/supervisor)

Company: _____

Site: _____

Plot: _____ Site manager/supervisor: _____

Ref.	Item	Yes (✓)	No (✓)	Inspected (initials & date)
1.	Are 100mm (min) Porotherm blocks used in separating wall?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
2.	Is separating wall cavity at least 100mm?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
3.	Are only the named 'Type A' wall ties installed at no more than 2.5 ties per square metre in separating wall?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
4.	Are insulation sections tightly butted together?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
5.	Is cavity free from droppings and debris?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
6.	Is Ecoparge (nominal 4mm, minimum 3mm) applied to both leafs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
7.	Is the separating wall free from service chasing?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
8.	Is external (flanking) wall inner leaf 100mm (min) Porotherm blocks with Ecoparge applied?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
9.	Is junction with flanking wall toothed using cut blocks and mortared perpend?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
10.	Is external (flanking) wall cavity at least 50mm?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
11.	Are cavity stops installed where specified in the robust detail™?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
12.	Are voids around floor joists fully filled/sealed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
13.	Are all junctions of wall and ceiling boards sealed with tape or caulked with sealant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
14.	Is separating wall satisfactorily complete?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>

Contact details for technical assistance from Wienerberger, supplier of Porotherm products:
Telephone: 0161 491 8200 Fax: 0161 491 6529 E-mail: Regional Tech Manager - see www.wienerberger.co.uk/blocks for contact information

Notes (include details of any corrective action)

 Site manager/supervisor signature

©: UK registered trade mark no. 2291665

™: trade mark

© Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.