CHECKLIST (to be completed by site manager/supervisor)

Company:

Site:

Plot: Site manager/supervisor:

Ref.	Item	Yes (✔)	No (✔)	Inspected (initials & date)
1.	Are wall leaves at least 40mm apart?			
2.	Are the metal frames a minimum of 72mm or greater?			
3.	Is the mineral wool placed in the cavities of both leaves?			
4.	Are all joints in the wall lining staggered?			
5.	Are all joints sealed with tape or caulked with sealant?			
6.	Is separating wall satisfactorily complete?			

Notes (include details of any corrective action)

Site manager/supervisor signature . . . . . .

Copyright in the contents of this handbook is owned by Robust Details Limited. No copying or reproduction of the contents is permitted without the consent of Robust Details Limited with the exception of the checklists. The checklists may be copied and used freely.